GOVERNMENT OF ODISHA
ENERGY DEPARTMENT
***

NOTIFICATION

No. 5728 /En, Bhubaneswar, Dated the 26/05/2026
ENG-RR-RR-0003-2017

1. In exercise of the powers conferred under Sub-regulation (1) of Regulation 38 and Sub-regulation (2) of Regulation-45 of the Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2023 and in supersession of all previous orders/instructions issued in this regard, the State Government hereby notifies the following with immediate effect.

   i. All electrical installations connected with electricity at voltage up to 33 kV shall be self-certified by the owner/supplier/consumer as the case may be, through certified Chartered Electrical Safety Engineers (CESEs) as opted by the owner/supplier/consumer in accordance with the provisions of the Electricity Act, 2003 and the rules/regulations made thereunder.

   ii. Notwithstanding anything contained in the above clause, the electrical installations covered under Section 54 of the Electricity Act, 2003 and the electrical installations of mines, oil fields and railways shall continue to be inspected and certified by the Electrical Inspector irrespective of voltage level.

   iii. The periodicity of inspection of electrical installations, as prescribed vide this Department Notification No. 10317 dated 27.10.2022 shall continue to be in force for installations inspected by both the Electrical Inspectorate and CESEs.

2. Further, in exercise of the powers conferred by Sub-Regulation (1) of Regulation-136 of the Central Electricity Authority (Measures relating to Safety nd Electric Supply) Regulations, 2023, the State Government do hereby allow the electrical installations belonging to Odisha Power Transmission Corporation Limited (OPTCL) up to 765 kV voltage level shall be inspected, tested and self-certified by themselves before commencement of supply or recommencement after shut down for six months or more.

3. In partial modification to this Department Notification No-7753 dated 27.10.2016, the State Government do here by notify that no consumer or occupier shall commission his/her generating plant generating electricity from any source of energy of a capacity above 500 KVA without the written approval of the Electrical Inspector.

By order of the Governor

26.5.2026

(S.B.K Pradhan)
Additional Secretary to Govt.

Memo No. 5729 /En, Dated. 26.05.2026

Copy along with soft copy (in MS Word format) forwarded to the Director, Printing Stationery and Publication, Odisha, Cuttack with a request to publish this notification in the next issue of Odisha extra ordinary gazette and to supply 50 (Fifty) copies thereof to this Department.

26.5.2026

Additional Secretary to Govt.

Memo No. 5730 /En, Dated. 26.05.2026

Copy forwarded to Private Secretary to Hon'ble Dy. Chief Minister, A&FE and Energy, Odisha for kind information Hon'ble Dy. Chief Minister.

26.5.2026

Additional Secretary to Govt.

Memo No. 5731 /En, Dated. 26.05.2026

Copy forwarded to OSD to Chief Secretary, Odisha/ Pr. PS to DC-cum-ACS/ Sr. PS to Additional Chief Secretary, Energy Department for kind information of Chief Secretary, Odisha/ DC-cum-ACS/ Additional Chief Secretary, Energy Department.

26.5.2026

Additional Secretary to Govt.

Memo No. 5732 /En, Dated. 26.05.2026

Copy forwarded to CMD, OHPC/ CMD, OPTCL/ EIC (EI)-cum-PCEI, Odisha/ MD, GRIDCO/MD, OPGC/ CE, OREDA/ CEO, TPCODL/ TPNODL/ TPWODL/ TPSODL/ GEDCOL/ OCPL for kind information.

26.5.2026

Additional Secretary to Govt.

Memo No. 5733 /En, Dated. 26.05.2026

Copy forwarded to all Officers/ all Sections, Energy Department for information.

26.5.2026

Additional Secretary to Govt.

Memo No. 5734 /En, Dated. 26.05.2026

Copy forwarded to Head, Portal Group, IT Centre, Lok Seva Bhawan for information and necessary action. It is requested to upload this notification in the website of Energy Department urgently.

26.5.2026

Additional Secretary to Govt.

GOVERNMENT OF ODISHA
ENERGY DEPARTMENT
***

NOTIFICATION

No. 7819 /En., Bhubaneswar, Dated the 07.07.2026
ENG-RR-RR-0003-2017

In partial modification to this Department Notification No.-5728, dated 26.05.2026 , the State Government, after careful consideration, have been pleased to notify that electrical installations belonging to different power utilities such as OHPC, OPGC and the DISCOMs up to 33kV voltage level shall be inspected, tested and self-certified by the qualified and experienced electrical engineers of the utility concerned, duly authorised by the concerned organisation, before commencement of supply or recommencement after shut down for six months or more in accordance with Central Electricity Authority (Measures related to Safety and Electric Supply) Regulation, 2023.

By order of the Governor

7.07.2026

(S.B.K Pradhan)
Special Secretary to Govt.

Memo No. 7820 /En, Dated. 07.07.2026
Copy along with soft copy (in MS Word format) forwarded to the Director, Printing Stationery and Publication, Odisha, Cuttack with a request to publish this notification in the next issue of Odisha extra ordinary gazette and to supply 50 (Fifty) copies thereof to this Department.

7.07.2026
Special Secretary to Govt.

Memo No. 7821 /En, Dated. 07.07.2026
Copy forwarded to Private Secretary to Hon'ble Dy. Chief Minister, A&FE and Energy, Odisha for kind information Hon'ble Dy. Chief Minister.

7.07.2026
Special Secretary to Govt.

Memo No. 7822 /En, Dated. 07.07.2026
Copy forwarded to OSD to Chief Secretary, Odisha/ Pr. PS to DC-cum-ACS/ Sr. PS to Additional Chief Secretary, Energy Department for kind information of Chief Secretary, Odisha/ DC-cum-ACS/ Additional Chief Secretary, Energy Department.

7.07.2026
Special Secretary to Govt.

Memo No. 7823 /En, Dated. 07.07.2026
Copy forwarded to the Chairman & MD, OHPC/ CMD, OPTCL/ EIC (EI)-cum-PCEI, Odisha/ MD, GRIDCO/MD, OPGC/ CE, OREDA/ CEO, TPCODL/ TPNODL/ TPWODL/ TPSODL/ GEDCOL/ OCPL for kind information.

7.07.2026
Special Secretary to Govt.

Memo No. 7824 /En, Dated. 07.07.2026
Copy forwarded to all Officers/ all Sections, Energy Department for information.

7.07.2026
Special Secretary to Govt.

Memo No. 7825 /En, Dated. 07.07.2026
Copy forwarded to Head, Portal Group, IT Centre, Lok Seva Bhawan for information and necessary action. It is requested to upload this notification in the website of Energy Department urgently.

7.07.2026
Special Secretary to Govt.