

GOVERNMENT OF ODISHA
DEPARTMENT OF ENERGY

Notification

No. 9588 /En.,
EL(Misc.)07/2016

Dated, 28/12/2016



In exercise of the powers conferred by sub-section (o) of section 180 of the Electricity Act, 2003 (36 of 2003) and section 162 of Electricity Act 2003 (36 of 2003) read with regulation 36 of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 with all its amendments, the Government of Odisha do hereby notify that Electrical Installations supplied with 400 Volts or more of all multi-storeyed buildings of more than fifteen meters in height shall be inspected by the Electrical Inspector before commencement or recommencement of supply after the installation has been disconnected for a period of six months or more.

By order of Governor

Addl. Secretary to Government

Memo No. 9589 /En.,

Dtd. 28/12/2016

Copy forwarded to the Director of Printing Stationery and Publication, Odisha, Cuttack for publication of the Notification (statutory) in the next issue of the Odisha Gazette and supply 50 copies of the Notification to this Department.

Addl. Secretary to Government

Memo No. 9590 /En.,

Dtd. 28/12/2016

Copy forwarded to the Head Portal IT Centre, Secretariat with a request to upload the notification in official website of Energy Department for information.

Addl. Secretary to Government

Memo No. 9591 /En.,

Dtd. 28/12/2016

Copy forwarded to Chairman-cum-Managing Director, GRIDCO/OPTCL, Bhubaneswar/CMD, OHPC, Bhubaneswar/MD, OPGC, Bhubaneswar/ Chief Engineer-cum-Chief Electrical Inspectors, Central Zone, Bhubaneswar/South Zone, Berhampur/ Western Zone, Sambalpur/North Eastern Zone, Balasore/ All Board Members of Electrical Licensing Board, Odisha for information.

Addl. Secretary to Government